

GOVERNMENT NOTICE NO 347 published on 8/5/2020

THE PETROLEUM ACT,

CAP.392

NOTICE

(Made under section 128)

THE PETROLEUM (LPG STORAGE AND FILLING PLANT NGORONGORO GAS
AND OIL COMPANY (T) LIMITED) (CONSTRUCTION APPROVAL) NOTICE, 2020

Citation

1. This Notice may be cited as the Petroleum (LPG
Storage and Filling Plant Ngorongoro Gas and Oil Company
(T) Limited) (Construction Approval) Notice, 2020.

Interpretation

2. In this notice, unless the context otherwise
requires-
“applicant” means Ngorongoro Gas and Oil Company (T)
Limited of P. O. Box 72465, Dar es Salaam;
“Authority” means the Energy and Water Utilities Regulatory
Authority established under the Energy and
Water Utilities Regulatory Authority Act; and
“construction approval” means an approval issued by the
Authority pursuant to section 128 of the
Petroleum Act.

Cap. 414

Cap.392

Grant of
construction
approval

3. The applicant is hereby granted a construction
approval to construct LPG Storage and Filling Plant on Plot
No. 2 Block ‘N’, Vijibweni Area in Kigamboni Municipality
in Dar es Salaam subject to the following conditions:
(a) bulk storage tanks and filling plants shall be
constructed in accordance with the applicable
international standard which is South African
National Standard - SANS 10087-3:2008;
(b) the layout of the facility shall meet the minimum

- safety distances in accordance with the applicable international standard which is South African National Standard - SANS 10087-3:2008;
- (c) there shall not be any aerial obstruction at the site;
 - (d) the storage tanks and associated pipelines shall be well protected from corrosion;
 - (e) the storage tanks and pumps together with the connecting pipes and fittings must be constructed so as to prevent any leakage;
 - (f) the storage tanks and associated pipelines system shall be pressure tested;
 - (g) the storage tanks and associated pipelines system shall undergo Non – Destructive Tests such as x-ray and ultrasound;
 - (h) the facility should be provided with appropriate fire-fighting system in accordance with the applicable international standard which is API Standard 2510A;
 - (i) there shall be clear and visible safety warning signs throughout the facility which include but not limited to "switch off engine", "switch off mobile phone" and "no smoking";
 - (j) the facility shall be well surfaced with impervious materials and there shall be no deep ditch in the surrounding to avoid LPG settling;
 - (k) the filling plant shall be located in a such manner that it allows manoeuvrability and at least 50ft from the storage tanks;
 - (l) the filling plant shall have a canopy or roof of a non-combustible material to provide weather protection and to protect the filling equipment from direct sunlight. The canopy or roof when fitted shall be at least 2.5 meters above floor level and so designed as to allow free movement of air past the filling equipment and operators;
 - (m) the facility shall be free from weeds, open drains, depressions etc. Weed killers which constitute fire hazard shall not be used to remove weeds at installation points; and
 - (n) the facility shall be well fenced with property

Troleum (Lpg Storage And Filling Plant Ngorongoro Gas And Oil Company (T) Limited)
(Construction Approval)

GN NO. 347(Conted)

boundary with at least two exits.

Expiry of
construction
approval

4. The construction approval shall automatically expire or cease to have effect if such construction fails to take effect within twenty-four months from the date of issue.

Dodoma
20th April, 2020

NZINYANGWA E. MCHANY
Director General