

GOVERNMENT NOTICE NO. 371 published on 15/5/2020

THE PETROLEUM ACT,
(CAP. 392)

NOTICE

(Made under section 128(3))

THE PETROLEUM (KIFARU OIL INVESTMENT LIMITED – MOIVARO PETROL
SERVICE STATION) (CONSTRUCTION APPROVAL) NOTICE, 2020

- | | |
|--------------------------------|---|
| Citation | 1. This Notice may be cited as the Petroleum (Kifaru Oil Investment Limited – Moivaro Petrol Service Station) (Construction Approval) Notice, 2020. |
| Interpretation | 2. In this Notice, unless the context otherwise requires:
“applicant” means Kifaru Oil Investment Limited – Moivaro Petrol Service Station of P.O. Box 1851 Moshi;
“Authority” means the Energy and Water Utilities Regulatory Authority established under the Energy and Water Utilities Regulatory Authority Act; and
“construction approval” means an approval issued by the Authority pursuant to section 128(1) of the Petroleum Act. |
| Cap. 414 | |
| Cap. 392 | |
| Grant of construction approval | 3. The applicant is hereby granted a construction approval to construct a petroleum products retail outlet at Plot No. 101, Block “F”, Moivaro Area, Arusha City Council in Arusha Region subject to the following conditions:

(a) the retail station shall be constructed in accordance with the Tanzania Bureau of |

Standards TZS 1115:2009 and TZS 1079:2009;

- (b) due care shall be exercised during excavation and installation of underground tanks;
- (c) the layout of the retail station shall meet the minimum safety distances in accordance with Tanzania Bureau of Standards TZS 1079:2009;
- (d) the underground tanks and associated pipelines shall be well protected from corrosion and the back filling shall be done properly using non-corrosive materials;
- (e) the underground storage tanks and pumps together with the connecting pipes and fittings shall be constructed so as to prevent any leakage of fuel;
- (f) underground storage tanks and dispensing pumps shall be calibrated by the Weights and Measures Agency established under the Weights and Measures Act;
- (g) the forecourt of the retail station shall be paved with impervious materials at the pump island with a drainage provision connected to oil and water separator;
- (h) an emergency shut off switch shall be installed in a conspicuous and accessible area;
- (i) ensuring that there shall be adequate and clean toilet facilities at all times;
- (j) clear and visible safety warning signs shall be installed at the entrance, exit and at the dispensing pumps, including "switch off engine", "switch off mobile phone" and "no smoking";
- (k) each storage tank shall be fitted with vent pipes with a minimum height of 3.6 metres;
- (l) each pump shall be protected with crash barriers with the height of one meter above

Cap 340

- the ground;
- (m) the offloading manhole shall be constructed in accordance with good petroleum industry practices and the offloading receiving pipes shall be provided with couplings to prevent spillages during offloading;
- (n) the retail station shall be covered with a canopy covering at least the pump island and constructed in accordance with good petroleum industry practices; and
- (o) a price board shall be erected in a conspicuous place.

Expiry of
construction
approval

4. The construction approval shall automatically expire or cease to have effect where such construction fails to take effect within twenty-four months from the date of issue.

Dodoma,
30th April, 2020

NZINYANGWA E. MCHANY
Director General