

GOVERNMENT NOTICE NO. 454 published On. 12/6/2020

THE PETROLEUM ACT,
(CAP. 392)

NOTICE

(Made under Section 128)

THE PETROLEUM (VIVO ENERGY TANZANIA LIMITED- MASAKI SERVICE STATION)
(CONSTRUCTION APPROVAL) NOTICE, 2020

- | | |
|-----------------------------------|--|
| Citation | 1. This Notice may be cited as the Petroleum (Vivo Energy Tanzania Limited- Masaki Service Station) (Construction Approval) Notice, 2020. |
| Interpretation | 2. In this Notice, unless the context otherwise requires-
“applicant” means Vivo Energy Tanzania Limited- Masaki Service Station of P.O. Box 78470 Dar es Salaam;
“Authority” means the Energy and Water Utilities Regulatory Authority established under the Energy and Water Utilities Regulatory Authority Act; and
“construction approval” means an approval issued by the Authority pursuant to section 128(1) of the Petroleum Act. |
| Cap. 414 | |
| Cap 392 | |
| Granting of construction approval | 3. The applicant is hereby granted a construction approval to construct a petroleum products retail outlet at Plot No. 2056 Masaki area in Kinondoni Municipality in Dar es Salaam Region subject to the following conditions:
(a) the retail station shall be constructed in accordance with the Tanzania Bureau of Standards TZS 1115:2009 and TZS |

1079:2009;

- (b) due care shall be exercised during excavation and installation of underground tanks;
- (c) the layout of the retail station shall meet the minimum safety distances in accordance with Tanzania Bureau of Standards TZS 1079:2009;
- (d) the underground tanks and associated pipelines shall be well protected from corrosion and the back filling shall be done properly using non-corrosive materials;
- (e) the underground storage tanks and pumps together with the connecting pipes and fittings shall be constructed so as to prevent any leakage of fuel;
- (f) underground storage tanks and dispensing pumps shall be calibrated by the Weights and Measures Agency established under the Weights and Measures Act;
- (g) the forecourt of the retail station shall be paved with impervious materials at the pump island with a drainage provision connected to oil and water separator;
- (h) an emergency shut off switch shall be installed in a conspicuous and accessible area;
- (i) ensuring that there are adequate and clean toilet facilities at all times;
- (j) clear and visible safety warning signs shall be installed at the entrance, exit and at the dispensing pumps, including "switch off engine", "switch off mobile phone" and "no smoking";
- (k) each storage tank shall be fitted with vent pipes with a minimum height of 3.6 metres;
- (l) each pump shall be protected with crash barriers with the height of one meter above the ground;

Cap 340

- (m) the offloading manhole shall be constructed in accordance with good petroleum industry practices and the offloading receiving pipes shall be provided with couplings to prevent spillages during offloading;
- (n) the retail station shall be covered with a canopy covering at least the pump island and constructed in accordance with good petroleum industry practices; and
- (o) a price board shall be erected in a conspicuous place.

Expiry of
construction
approval

4. The construction approval shall automatically expire or cease to have effect where such a construction fails to take effect within twenty four months from the date of issue.

Dodoma
4th June, 2020

GODFREY H. CHIBULUNJE
Director General