

GOVERNMENT NOTICE NO. 609 published on 7/8/2020

THE PETROLEUM ACT,
(CAP. 392)

NOTICE

(Made under section 128)

THE PETROLEUM (MCHOMVU COMPANY LIMITED – SAME PETROL STATION)
(CONSTRUCTION APPROVAL) NOTICE, 2020

- | | |
|-------------------------------------|---|
| Citation | 1. This Notice may be cited as the Petroleum (Mchomvu Company Limited – Same Petrol Station) (Construction Approval) Notice, 2020. |
| Interpretation | 2. In this Notice, unless the context otherwise requires-
“Applicant” means Mchomvu Company Limited – Same Petrol Station of P.O. Box 80 Same. |
| Cap. 414 | “Authority” means the Energy and Water Utilities Regulatory Authority established under the Energy and Water Utilities Regulatory Authority Act; and |
| Cap. 392 | “construction approval” means an approval issued by the Authority pursuant to section 128 (1) of the Petroleum Act. |
| Granting of a construction approval | 3. The applicant is hereby granted a construction approval to construct a petroleum products retail outlet at Plot No. 13 & 15, Block “HHH”, Same Urban Area, Same District in Kilimanjaro Region:
(a) the retail station shall be constructed in accordance with the Tanzania Bureau of Standards TZS 1115:2009 and TZS 1079:2009;
(b) due care shall be exercised during excavation and installation of underground tanks;
(c) the layout of the retail station shall meet the minimum safety distances in accordance with Tanzania Bureau of Standards TZS 1079:2009;
(d) the underground tanks and associated pipelines shall be well protected from corrosion and the back filling shall be done properly using non-corrosive materials;
(e) the underground storage tanks and pumps together with the connecting pipes and fittings shall be constructed so as to prevent any leakage of fuel;
(f) underground storage tanks and dispensing pumps shall be calibrated by the Weights and Measures Agency established under the Weights and Measures Act;
(g) the forecourt of the retail station shall be paved with impervious materials at the pump island with a drainage provision connected to oil and water separator;
(h) an emergency shut off switch shall be installed in a |

Petroleum (Mchomvu Company Limited – Same Petrol Station) (Construction Approval)

	conspicuous and accessible area;
	(i) ensuring that there shall be adequate and clean toilet facilities at all times;
	(j) clear and visible safety warning signs shall be installed at the entrance, exit and at the dispensing pumps, including "switch off engine", "switch off mobile phone" and "no smoking";
	(k) each storage tank shall be fitted with vent pipes with a minimum height of 3.6 metres;
	(l) each pump shall be protected with crash barriers with the height of one meter above the ground;
Cap. 340	(m) the offloading manhole shall be constructed in accordance with good petroleum industry practices and the offloading receiving pipes shall be provided with couplings to prevent spillages during offloading;
	(n) the retail station shall be covered with a canopy covering at least the pump island and constructed in accordance with good petroleum industry practices; and
	(o) a price board shall be erected in a conspicuous place.
Expiry of construction approval	4. The construction approval shall automatically expire or cease to have effect where such construction fails to take effect within twenty-four months from the date of issue.

Dodoma
27th July, 2020

GODFREY H. CHIBULUNJE
Director General