

GOVERNMENT NOTICE NO 611 published on 7/8/2020

THE PETROLEUM ACT,
(CAP. 392)

NOTICE

(Made under section 128)

THE PETROLEUM (MHELE COMMERCIAL AGENCIES LTD PETROL STATION)
(CONSTRUCTION APPROVAL) NOTICE, 2020

Citation	1. This Notice may be cited as the Petroleum (Mhele Commercial Agencies Ltd Petrol Station) (Construction Approval) Notice, 2020.
Interpretation	2. In this Notice, unless the context otherwise requires- “applicant” means Mhele Commercial Agencies Ltd Petrol Station of P.O. Box 32604, Dar es Salaam; “Authority” means the Energy and Water Utilities Regulatory Authority established under the Energy and Water Utilities Regulatory Authority Act; and
Cap. 414	
Cap. 392	“construction approval” means an approval issued by the Authority pursuant to section 128(1) of the Petroleum Act.
Granting of construction approval	3. The applicant is hereby granted a construction approval to construct a petroleum products retail outlet at Plot No. 292 Block ‘A’, Kerege area, Bagamoyo District in Coast Region subject to the following conditions: (a) the retail station shall be constructed in accordance with the Tanzania Bureau of Standards TZS 1115:2009 and TZS 1079:2009; (b) due care shall be exercised during excavation and installation of underground tanks; (c) the layout of the retail station shall meet the minimum safety distances in accordance with Tanzania Bureau of Standards TZS 1079:2009; (d) the underground tanks and associated pipelines shall be well protected from corrosion and the back filling shall be done properly using non-corrosive materials; (e) the underground storage tanks and pumps together with the connecting pipes and fittings shall be constructed so as to prevent any leakage of fuel; (f) underground storage tanks and dispensing pumps shall be calibrated by the Weights and Measures Agency established under the Weights and Measures Act; (g) the forecourt of the retail station shall be paved with impervious materials at the pump island with a drainage provision connected to oil and water separator; (h) an emergency shut off switch shall be installed in a conspicuous and accessible area;

- Cap 340
- (i) ensuring that there shall be adequate and clean toilet facilities at all times;
 - (j) clear and visible safety warning signs shall be installed at the entrance, exit and at the dispensing pumps, including "switch off engine", "switch off mobile phone" and "no smoking";
 - (k) each storage tank shall be fitted with vent pipes with a minimum height of 3.6 metres;
 - (l) each pump shall be protected with crash barriers with the height of one meter above the ground;
 - (m) the offloading manhole shall be constructed in accordance with good petroleum industry practices and the offloading receiving pipes shall be provided with couplings to prevent spillages during offloading;
 - (n) the retail station shall be covered with a canopy covering at least the pump island and constructed in accordance with good petroleum industry practices; and
 - (o) a price board shall be erected in a conspicuous place.
- Expiry of construction approval
4. The construction approval shall automatically expire or cease to have effect where such construction fails to take effect within twenty-four months from the date of issue.

Dodoma
20th July, 2020

GODFREY H. CHIBULUNJE
Director General