

GOVERNMENT NOTICE No. 189 published on 8/4/2022

THE PETROLEUM ACT,  
(CAP.392)

**NOTICE**

*(Made under section 128)*

THE PETROLEUM (ALLYEN COMPANY LIMITED-MJIMWEMA FILLING STATION)  
(CONSTRUCTION APPROVAL) NOTICE, 2022

- Citation 1. This Notice may be cited as the Petroleum (Allyen Company Limited-Mjimwema Filling Station)(Construction Approval) Notice, 2022.
- Interpretation 2. In this Notice, unless the context otherwise requires:  
“applicant” means Allyen Company Limited-Mjimwema Filling Station of P.O Box 36105, Dar es salaam;  
“Authority” means the Energy and Water Utilities Regulatory Authority established under the Energy and Water Utilities Regulatory Authority Act; and  
“construction approval” means an approval issued by the Authority pursuant to section 128(1) of the Petroleum Act.
- Cap. 414
- Cap. 392
- Granting of construction approval 3. The applicant is hereby granted a construction approval to construct a petroleum products retail outlet at Plot No. 897 Block B, Mjimwema area, Kigamboni Municipality in Dar es Salaam Region subject to the following conditions:  
(a) the retail station shall be constructed in accordance with the Tanzania Bureau of Standards TZS 1115:2009 and TZS 1079:2009;

Cap. 340

- (b) due care shall be exercised during excavation and installation of underground tanks;
- (c) the layout of the retail station shall meet the minimum safety distances in accordance with Tanzania Bureau of Standards TZS 1079:2009;
- (d) the underground tanks and associated pipelines shall be well protected from corrosion and the back filling shall be done properly using non-corrosive materials;
- (e) the underground storage tanks and pumps together with the connecting pipes and fittings shall be constructed so as to prevent any leakage of fuel;
- (f) underground storage tanks and dispensing pumps shall be calibrated by the Weights and Measures Agency established under the Weights and Measures Act;
- (g) the forecourt of the retail station shall be paved with impervious materials at the pump island with a drainage provision connected to oil and water separator;
- (h) an emergency shut off switch shall be installed in a conspicuous and accessible area;
- (i) there shall be adequate and clean toilet facilities at all times;
- (j) clear and visible safety warning signs shall be installed at the entrance, exit and at the dispensing pumps, including "switch off engine", "switch off mobile phone" and "no smoking";
- (k) each storage tank shall be fitted with vent pipes with a minimum height of 3.6 metres;
- (l) each pump shall be protected with crash barriers with the height of one meter above the ground;
- (m) the offloading manhole shall be constructed in accordance with good petroleum industry practices and the offloading receiving pipes

- shall be provided with couplings to prevent spillages during offloading;
- (n) the retail station shall be covered with a canopy covering at least the pump island and constructed in accordance with good petroleum industry practices; and
  - (o) a price board shall be erected in a conspicuous place.

Expiry of  
construction  
approval

4. The construction approval shall automatically expire or cease to have effect if such construction fails to take effect within twenty-four months from the date of issue.

Dodoma  
....., 2022

GODFREY H. CHIBULUNJE  
*Director General*